

Slump Cone Calibration Worksheet

Equipment ID: _____ Date: _____
Manufacturer: _____ Performed by: _____
Model #: _____
Serial #: _____ Next Calibration Due: _____
Storage Location: _____ Last Calibration: _____

Calibration Item: Verify critical dimensions of the cone

Calibration Procedure: In-House Procedure

Thickness of cone: _____	Tolerance = Not less than 0.060 inches
Bottom Inside Diameter of Cone: _____	Tolerance = 8 +/- 1/8 inches
Top Inside Diameter of Cone: _____	Tolerance = 4 +/- 1/8 inches
Height of Cone: _____	Tolerance = 12 +/- 1/8 inches
Cone Interior Smooth: _____	Pass/Fail
Base and top opening parallel: _____	Pass/Fail
	Pass/Fail: _____

Comments: _____

Initial By: _____